



City of Seattle Preliminary Assessment Report

March 08, 2010

This report represents a preliminary determination of project requirements from various city departments. The report is based on project characteristics that you identified on the Site Plan and the Preliminary Application Form. The city's goal is to provide you with as much information and assistance as possible prior to your permit application submittal. This coordinated list of requirements and decisions is a reference for creating a more complete submittal package to reduce the need for correction cycles that delay permit approval. The information in this report can also be used to develop a Street Improvement Plan (SIP) application for submittal to SDOT (see SDOT Client Assistance Memos 2200, 2201, 2211, 2212, 2213, and 2214).

Note: A preliminary assessment is being conducted on all land use projects as well as new construction projects. If you have a building project associated with your land use project, the preliminary assessment will not be repeated on the building project.

The applicant assumes full responsibility for determining all permit requirements and infrastructure improvements per applicable sections of the Seattle Municipal Code and the City of Seattle's Right-of-Way Improvement manual.

- Street use permits are required for all work in the right-of-way (see SDOT Client Assistance Memo 2100).
- If street improvements are required, you must obtain all necessary permits from SDOT.
- If an SIP is required, SDOT must accept your 90% complete SIP before DPD construction intake (see Client Assistance Memos 2200, 2206, 2209, 2211, 2213, and 2214).

Project Summary			
AP/Project No.	3010906	Ground Disturbance	
Application Template	PRJ	PASV Required This Permit	N
Application Type	DISCRETIONARY LAND USE ACTION	Date PASV Completed	(Not Req)
Category	SINGLE FAMILY / DUPLEX	PASV Done Under	6133372
DPD Review Type	FULL C	Permit Remarks	6133372 2/17/10 APPLICATION REJECTED, SEE HWT NOTES
Address	3700 E Valley St		
Location			
Zoning		Applicant	KOZO NOZAWA 224 W GALER ST SEATTLE WA 98119 (206) 283-9930
King County APN	5317100485		
Permit Status	Initial Information Collected	Applicant Email Linked AP/Project Nos.	KOZO@PRENTISSARCH.COM
Description of Work	Land use application to allow a 2200 sq.ft. sfr in an environmentally critical area. Existing structures to be demolished.		
SDOT Project No			

For detailed zoning information, click the King County APN number above, or visit <http://web1.seattle.gov/dpd/parceldata/> to find zoning details about your address.

Seattle City Light Requirements

Contact: Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Street/Alley Requirements E VALLEY ST

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10, Electrical Conduit and Facilities in the Public Rights of Way

(<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground high & low voltage lines & electrical vaults along E Valley St.

Other Requirements

- For new service, an Application for Electrical Service must be submitted to Seattle City Light. Please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. The Electrical Service Representative should also be contacted to coordinate electrical details with demolition and temporary power for construction. Your Electrical Service Representative is: Jason Chollette, 206-684-4977, jason.chollette@seattle.gov

DPD Drainage Requirements

Contact: Michelle M Macias, (206) 684-3068, michelle.macias@seattle.gov

The following requirements are based on the current stormwater and side sewer codes. Major updates to these codes are expected in the fourth quarter of 2009.

Existing Public Drainage Infrastructure

Sanitary sewer main location: Hillside Dr E

Sanitary sewer main size: 10-inch

Storm drainage main location: Hillside Dr E

Storm drainage main size: 18-inch

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: On site (infiltration). With geotechnical evaluation and approval.

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. Refer to CAM 531, Post Construction Soil Management. For projects with 5,000 square feet or more of new plus replaced impervious surface, a comprehensive drainage control plan and construction stormwater control plan shall be prepared by a licensed engineer.

All single-family residential projects shall implement green stormwater infrastructure (GSI) to the maximum extent feasible per SMC 22.805.030. Refer to CAMs 530-537 - Green Stormwater Infrastructure on Private Property. Refer to Director's Rule 19-2009 - Requirements for Green Stormwater Infrastructure to the Maximum Extent Feasible. Submit a Standard Drainage Control Plan for Single Family Projects that includes a GSI Calculator per DR 19-2009.

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge (DPD DR 3-2006/SPU DR 02-06 VII.H) is located at the following: Onsite (infiltration). With geotechnical evaluation and approval.

Other Requirements

- See PAR prepared under 6133372.

DPD Land Use Code Requirements

Contact: Christopher Amba Ndifon, (206) 684-5046, christopher.ndifon@seattle.gov

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

E VALLEY ST

Drainage will be required to be installed in the portion of right-of-way abutting this lot. If you need further clarification, contact SDOT for further information or apply for SDOT SIP design guidance (see SDOT CAM 2211).

New structures must be designed to accommodate future right-of-way improvements. To ensure that driveways and pedestrian access points are designed to match these future street improvements, please use the Building Grade Calculator, which can be found at <http://www.seattle.gov/transportation/gradesheetintro.htm>

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found at http://www.seattle.gov/dpd/static/Covenant_Consenting_LID_LatestReleased_DPDS_006060.pdf

A vehicular turnaround/cul-de-sac is required when street or alley dead-ends at the property to be developed. Apply for SDOT SIP design guidance (see SDOT CAM 2211).

Land Use

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

Based on the preliminary scope, the project may qualify for a specific exemption under the Environmentally Critical Areas Ordinance. Application and decision on the exemption must be made before submittal of a application. See CAM 327 for more details.

Development within a steep slope or steep slope buffers requires a steep slope area variance. See CAM 330 for more details.

Based on the preliminary site plan, a yard or setback reduction variance is required. See CAM 330 for details.

Modifications to parking quantity, floor area ratio, and height due to development within a peat bog require submittal of a geotech report. See CAM 325 for more details.

SDOT Requirements

Contact: Matthew Tabalno, matthew.tabalno@seattle.gov

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

Initial Review Deposit: \$1,250

SDOT Plan Requirements: Engineered plan

SDOT Permit Requirements: Group 3: Street Use Major (Type 45). A 90% complete street improvement plan (SIP) must be accepted by SDOT prior to your DPD construction intake appointment. Please visit SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_sip.htm to obtain SDOT Client Assistance Memos (CAMs) and application materials to assist in developing your street improvement plan (SIP).

Street Improvement Requirements

E VALLEY ST

New/replacement turnaround/cul-de-sac: See Seattle Right of Way Improvements Manual (ROWIM) section 4.22. If your project is proposing to install new turnaround/cul-de-sac or is proposing to change the alignment of an existing turnaround/cul-de-sac apply for SDOT SIP Design Guidance. See SDOT CAM 2211.

SPU Requirements

Contact: Jennyfer Jacobsen, (206) 684-8766, JacobsJS@seattle.gov

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. Refer to CAM 501. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

Roadway projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible without causing flooding, landslide, or erosion impacts per SMC 22.802.020.F. Flow control standards must be first met by utilizing green stormwater infrastructure to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using green stormwater infrastructure. Refer to DR Parcel-MEF and DR Vol.3.

Stormwater Treatment

No requirements

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD CAM 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to CAM 208 for information regarding the application requirements for a SEPA review and CAM 3000 for information regarding landmarks and historic preservation.

Applicant Next Steps

For questions on the permit application process, please contact the Applicant Services Center (ASC) at 206-684-8850.

1. Review the requirements in this report.
2. Use Client Assistance Memos (CAMs), checklists and standards, and 5 Steps for a Successful DPD Application Submittal (available on the DPD website) for additional information.
3. If a SIP is required, **DPD will not accept your application until your SIP application is screened at SDOT**. Allow a minimum of 5 days for screening after application submittal to SDOT.
4. Information on requirements for Electric Service Connection (RESC), electric service applications, guidelines and other services can be found on Seattle City Light's website (<http://www.seattle.gov/light/newconstruction/>). Contact an Electric Service Representative for your electrical service design and connection questions:
North of Denny Way (206) 615-0600
South of Denny Way (206) 386-4200
Large Commercial & Industrial (206) 233-7177
Service Applications (206) 233-APPS (2777)
5. If you have additional questions or need additional information, you may request a pre-submittal conference. Call (206) 684-8850 or go to DPD's website (http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp).
6. When all issues have been addressed, you may schedule an intake appointment with DPD. **Please bring a copy of this report to your intake appointment.**

The requirements and determinations in this report are based on the details provided by the applicant on the preliminary application form and site plan submitted to DPD. If the scope of your proposed project changes before your DPD intake appointment or SDOT SIP application, the requirements in this report are subject to change. If there are municipal code and ordinance changes prior to your DPD intake, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.